Citation for published version:

Mentink, M, Van Duren, B, Murray, D & Gill, H 2017, 'A novel flexible capacitive load sensor for use in a mobile unicompartamental knee replacement bearing: an in vitro proof of concept study', *Medical Engineering & Physics*, vol. 46, pp. 44-53. <https://doi.org/10.1016/j.medengphy.2017.05.002>

DOI:

[10.1016/j.medengphy.2017.05.002](https://doi.org/10.1016/j.medengphy.2017.05.002)

Publication date:

2017

Document Version

Peer reviewed version

[Link to publication](#)

Publisher Rights

CC BY-NC-ND

University of Bath

Alternative formats

If you require this document in an alternative format, please contact:
openaccess@bath.ac.uk

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Title:

A novel flexible capacitive load sensor for use in a mobile unicompartmental knee replacement bearing: an *in vitro* proof of concept study

Authors:

Mentink M J A, michiementink@gmail.com, Nuffield Dept. of Orthopaedics, Rheumatology & Musculoskeletal Sciences, University of Oxford, Botnar Research Centre, Oxford, OX3 7LD, UK

Van Duren, B H, b.h.vanduren@gmail.com, Nuffield Dept. of Orthopaedics, Rheumatology & Musculoskeletal Sciences, University of Oxford, Botnar Research Centre, Oxford, OX3 7LD, UK

Murray D W, david.murray@ndorms.ox.ac.uk, Nuffield Dept. of Orthopaedics, Rheumatology & Musculoskeletal Sciences, University of Oxford, Botnar Research Centre, Oxford, OX3 7LD, UK

Gill H S, r.gill@bath.ac.uk, Department of Mechanical Engineering, University of Bath, Bath, BA2 7AY, UK

Corresponding author: michiementink@gmail.com

Keywords

Tibiofemoral forces, capacitive load sensor, in vitro, load measurement, UHMWPE mechanical behaviour, flexible sensor, polyimide.

Acknowledgements

21 Biomet (Biomet UK Ltd, Swindon, UK) helped with compression moulding of the instrumented
22 bearings.

23

24 **Competing interests**

25 One of the authors (DWM) receives royalty and consultancy payments related to
26 unicompartmental knee replacement.

27 **Funding:**

28 This work was supported by an NIHR Senior Investigator Award made to Professor David Murray,
29 April 2009 - March 2013.

30

31 **Ethical approval:**

32 Not required

33 **Abstract**

34 Instrumented knee replacements can provide *in vivo* data quantifying physiological loads acting
35 on the knee. To date instrumented mobile unicompartamental knee replacements (UKR) have not
36 been realised. Ideally instrumentation would be embedded within the polyethylene bearing. This
37 study investigated the feasibility of an embedded flexible capacitive load sensor. A novel flexible
38 capacitive load sensor was developed which could be incorporated into standard manufacturing
39 of compression moulded polyethylene bearings. Dynamic experiments were performed to
40 determine the characteristics of the sensor on a uniaxial servo-hydraulic material testing machine.
41 The instrumented bearing was measured at sinusoidal frequencies between 0.1 and 10 Hz,
42 allowing for measurement of typical gait load magnitudes and frequencies. These correspond to
43 frequencies of interest in physiological loading. The loads that were applied were a static load of
44 390 N, corresponding to an equivalent body weight load for UKR, and a dynamic load of ± 293 N.
45 **The frequency transfer response of the sensor suggests a low pass filter response with a**
46 **-3dB frequency of 10 Hz.** The proposed embedded capacitive load sensor was shown to be
47 applicable for measuring *in vivo* loads within a polyethylene mobile UKR bearing.

48

49

1 Introduction

Mechanical loads experienced by human joints during functional activities play an important role in the initiation and progression of osteoarthritis (OA) resulting in joint degeneration [1, 2]. The ability to measure the loads that occur within joints *in vivo* can give a valuable insight into the disease process. Measuring joint loads *in vivo* presents many challenges; both technologically and ethically.

Previously studies have attempted to estimate the mechanical forces and moments in the knee from external gait measurements [3], mechanical simulations (*in vitro* assessment) [4], computer simulations [5, 6], and telemetered implants. However, these methods have shortcomings. Force calculations from external gait measurements are subject to a large number of assumptions. The accuracy of simulations is dependent on the data provided by measurements, for instance from telemetered implants [6]. Forces measured *in vivo* using those implants are reported to be lower than those calculated by models [7].

In recent decades, instrumented Total Knee Replacement (TKR) implants have been successfully used to measure joint loading. In TKR many of the important structures of the knee, such as the cruciate ligaments, are removed during surgery resulting in a significant change in the kinematics of the knee. Instrumented TKR implants may require additional bone volume to be removed in order to accommodate the added volume of the instrumentation [8-10]. In contrast during Unicompartmental Knee Replacement (UKR) most of the structures are left intact, particularly the cruciate ligaments, resulting in kinematics that more closely represent those of the normal knee [10-15].

Instrumentation of UKR potentially offers valuable data describing the loads experienced in the knee. To our knowledge an instrumented Unicompartmental Knee Replacement (UKR) has not

76 been developed. With UKR it is important to retain as much bone as possible. Therefore, the
77 electronics need to be fitted within the implant components without requiring the removal of
78 additional knee structures.

79 In the Oxford mobile bearing UKR (ZimmerBiomet Ltd, Swindon, UK), the majority of the load is
80 perpendicular to the tibial tray, owing to the bearing being mobile in the transverse and sagittal
81 planes. Therefore, embedding a sensor within the bearing may offer the least intrusive method of
82 measuring load. Strain gauges have been used to measure forces in TKR implants. However,
83 previous work suggested that stress levels within an Oxford UKR bearing could rise as high as 5
84 MPa [16], which translates to 0.015 strain. Given that the fatigue life of typical Constantan strain
85 gauges falls below 10^5 cycles for strains of ± 0.002 [17], using strain gauges to measure UHMWPE
86 deformation directly would result in an unacceptably short sensor life, compared to the 16×10^6
87 loading cycles typically experienced by a UKR [16].

88 Capacitive sensors suffer less from a limited life span as the material under load can more readily
89 be chosen to be able to withstand load. Additionally, insertion of components with an elastic
90 modulus that is dissimilar to UHMWPE may cause stress risers and promote damage of the
91 bearing [16], whereas capacitive sensors can be designed to be more compliant, because sensor
92 materials and electrode construction can be adjusted to closely match the mechanical properties
93 of the host component. Polymer based capacitive sensors have previously been used to measure
94 forces [18-25] but never to measure forces within joints and they have never been incorporated
95 into industrial production process used in producing polyethylene bearings.

96
97 The aim of the current study was to investigate the feasibility of using a capacitive load sensor
98 embedded in an existing design of a mobile bearing used in a UKR implant in order to measure
99 loads acting on the knee. The minimum design specification for the sensor was that it should be
100 able to measure static load equivalent to one body weight during one leg stance, which was
101 defined as 780 N. The distribution of load between the condyles has been considered to have a

102 50/50 medial to lateral distribution [26-28], resulting in a static load of 390 N to be measured.
103 Furthermore, the sensor should be able to measure a maximum expected frequency content of
104 4.2 Hz [29]; we therefore choose to use a conservative measurement frequency of 10 Hz. The
105 sinusoidal load was set to be $\pm 75\%$ or $\pm 293\text{N}$ of the static load, to prevent lift-off of the actuator
106 at minimum load during testing. The specification for physical dimensions required the sensor to
107 fit within the existing Oxford UKR bearing, giving a maximum size of $5 \times 5 \times 0.2 \text{ mm}$.
108 The construction of the UKR bearing with an embedded capacitive load sensor is detailed
109 followed by *in vitro* tests to determine the characteristics of the capacitive load sensor embedded
110 within a polyethylene UKR bearing.

111

2 Methods

Instrumented Bearing Design & Construction:

The Oxford UKR uses a fully conforming mobile bearing resulting in the predominant load being in the proximal-distal orientation normal to the tibial plateau. Therefore a capacitive sensor, consisting of parallel plates, placed within the centre of the bearing was designed.

The capacitance of two parallel plates can be calculated using the equation (*equation 1*):

Equation 1

$$C = \frac{\epsilon_0 * \epsilon_r * A}{d}$$

where: capacitance, ϵ_0 = permittivity of free space, $8.85e-12$ F/m, ϵ_r = relative dielectric constant, A = overlapping area of two parallel electrodes [m^2], d = distance between electrodes [m]

When a load is applied to the sensor, the separation of the plates decreases, hence the capacitance increases. A sensor was developed which consisted of three copper layers (*Figure 1, Figure 2*), of which the outer two layers were electrically connected, resulting in a doubling of capacitance with respect to *Equation 1*, and providing shielding of the sensitive inner electrodes from electromagnetic interference by the common driven electrodes. The middle layer consisted of four electrodes (each with dimensions 2x2 mm) with an in-plane electrode separation of 0.5 mm. On the outer layers, there was a 5x5 mm common electrode. Together they formed four individually addressable capacitors. Polyimide (PI), a commonly used material for making flexible electronic circuits, was used for the dielectric layer. The total thickness of the sensor was 111 μm . The distance d between the electrodes was 44 μm , the area A of one electrode was $4E-6$ m^2 . The

capacitive sensor was kept small, primarily to retain as much of the mechanical integrity of the UHMWPE as possible, and secondarily to remain within the bounds of the maximum capacitance that the chosen Capacitive to Digital converter (C2D, AD7746 v2.2.2 Analog Devices Inc, Norwood, MA, USA) could measure. The capacitance of each electrode was measured to be nominally 16 pF, including the measurement leads (*Figure 3*). The flexible capacitive force sensor printed circuit board was designed using the OrCAD 16.5 (Cadence Design Systems, San Jose, CA, USA). The sensors, designed by MM, were manufactured by Sunsoar Tech (Sunsoar Tech, Shenzhen, China), using standard Polyimide material 'SYE'. The C2D was used to send a signal to the common electrode and the electrode with the strongest load response was connected to the input of the C2D. This design was chosen because of its small size and potential for possible application in a future production instrumented knee replacement bearing.

In order to be able to embed the sensor directly under the centre of the bearing concavity, the flexible sensor was shaped with limbs to position the electrodes in the middle of the bearing (*Figure 3a*) during the moulding process. The sensor leads were folded in a harmonica-like manner so as to enable their release after the moulding process had been completed. The first step in the moulding process was to place a layer of half the required amount of UHMWPE powder in the bottom of the moulding tool for the UKR bearing. The sensor was then placed on top of this layer (*Figure 3b*), and the remaining UHMWPE powder added. With the mould filled, the normal production temperature and pressure profiles were used to mould the bearing (*Figure 3c*) [30]. Using a hot cutting tool, the UHMWPE covering the folded sensor lead was removed, and the lead was extended (*Figure 3d*). After that, the shielded connecting leads were soldered to each sensor lead for measurement. Five instrumented left sided, large, size 6, Phase 3, Oxford UKR knee bearings were made. The length and the width of the bearings were approximately 36x24 mm. The distance from the bottom of the bearing to the lowest point of the bearing concavity was 6.5 mm.

160

161 **Sensor Testing:**

162 In order to calibrate a given sensor, measurement of the linear load response to an increasing
163 load is considered the gold standard [31]. However, UHMWPE is a polymer with viscoelastic
164 properties [30, 32] resulting in the response under load being time dependent. With continuous
165 compressive loads there is a gradual viscous response and for dynamic loads a rapid elastic
166 response. A simplified representation of loading was utilized to compensate for the viscous
167 response of UHMWPE: Loading of the knee joint can be considered to be the sum of two loading
168 components: static loading resulting from gravitational force, and superimposed dynamic loading
169 during dynamic gait activities. Pre-loading of a material, representing the gravitational force,
170 minimizes the viscous response resulting in a predominantly linear response to dynamic loads
171 experienced during the gait cycle.

172

173 To characterize the static and dynamic responses of UHMWPE, two experiments were conducted:
174 1) Initial pre-loading of UHMWPE to measure the duration of the viscous response to a step
175 change in loading
176 2) Successive application of sinusoidal frequencies superimposed on the static pre-load in order
177 to measure linearity of the system response.

178 These experiments were conducted using: a) A set of naked (unembedded) sensors (n=5) and b)
179 A set of UKR bearings with the sensor embedded (n=5).

180

181 The experiments were designed to address the following questions:

- 182 • How long should a static load be applied before the viscous response is sufficiently
183 reduced so as not to influence the dynamic measurements?
184 • What is the frequency response of the embedded load sensor?

- What distortion components are introduced to the measured signal?

A uniaxial servo-hydraulic material testing machine (Dartec DC10, Zwick, Leominster, UK) controlled by TIAB software version SR2 v2.06.17 (TIAB Ltd, Middleton Cheney, UK) was used to apply loads. Load data were sampled at 100 Hz, using a load cell (DSCRCM-15KN, Zwick, Leominster, UK, calibrated to 10 kN, resolution 0.5 N). Compression was measured with the built-in Dartec LVDT. For C2D measurement, the AD7746 demonstration kit (Analog Devices Inc, Norwood, MA, USA), was used, and the accompanying software was adjusted 1) to automatically apply a capacitance offset at the onset of the measurement using the built in CAPDAC (a programmable static capacitive offset) of the AD7746 to enable measurement of large capacitance values, 2) to log data with time stamps, and 3) to measure at 90 samples per second. Room temperature was monitored by an external thermocouple temperature sensor (SE002 Type K, Pico Tech, Eaton Socon, UK).

To test the naked sensors 5x5x5 mm glass cubes were bonded to five sensor foils with a poly-acrylate adhesive and mounted in the servo-hydraulic testing machine. The glass cubes provided a separation of the metal actuator of the testing machine from the electrodes and ensured that load was applied only to the electrode surface area. For the UKR bearing with embedded sensors, loads were applied using a stainless steel component with the same radius and width as a large UKR femoral component (Biomet UK Ltd, Swindon, UK), mounted in the servo-hydraulic testing machine (*Figure 4*).

Testing was conducted according to the protocol below:

- 1) 10 minutes warm up of all equipment before start of experiment
- 2) Adjustment of C2D input range, using the built-in capacitive offset of the C2D
- 3) Start of measurement, record unloaded capacitance

4) Static load applied for 15 minutes to approach creep equilibrium (pre-loading). The total static knee load due to gravity was assumed to be 780 N, and the maximum static load on the medial side of the knee was approximated as being 50% [26-28], or 390 N.

5) Sinusoidal loading applied (frequency response measurements, see further details below)

6) Unloaded rest interval of 15 minutes

The above testing protocol was repeated five times per sensor/bearing (as previously mentioned n=5 for both naked sensors and instrumented bearings).

Frequency Response Measurements: The maximum signal frequency was determined to be 10 Hz based on Fourier analysis of *in vivo* gait and step up/down measurements obtained from www.orthoload.com [29]. Sinusoidal loading frequencies from 0.1 to 1 Hz in steps of 0.1 Hz and 1 to 10 Hz in steps of 1 Hz were applied to the test setup, each for 10 seconds, and the sensor output was measured. Frequencies lower than 0.1 Hz were not measured due to time constraints. A static load of 100 N and a dynamic sine wave load of ± 33 N peak amplitude were applied to the upper glass cube for the naked sensor setup and a static load of 390 N with a dynamic sine wave of ± 293 N amplitude were applied to the UKR bearings embedded with the prototype sensor. A single sine model was fitted to both the measured loads and the resulting capacitance; the resulting fitted load amplitude was used to normalize the capacitance amplitude, in order to compensate for minor variations in loading amplitude.

Harmonic Distortion Analysis: Harmonic distortion analysis reveals the generation of higher order frequency components. Harmonic distortion was analysed using the normalised data that was used for the frequency response. To measure the harmonic distortion for each frequency (generation of higher harmonic frequencies), a dual sine wave model was fitted to the normalized measurement data.

237

238 *Sensitivity Calculation:* In order to compare the results with other work [19], the sensitivity (F/N)
239 was calculated, as well as the stress sensitivity (F/MPa), using a load of 33 N, and a surface
240 area of $2.5 \times 10^{-5} \text{ m}^2$ (from $[5 \times 10^{-3}]^2$).

241 All analyses were performed using custom scripts written in Matlab 8.2 (R2013b) (The
242 mathworks Inc, Natick, Massachusetts, USA)

3 Results

For all sensors the capacitance increased as load was increased, cycling the load led to a cycling of the capacitance values tracking the load. *Figure 5* provides an exemplar plot of the measured capacitance with time graph for a single test, showing the resulting loading pattern with an initial static pre-load and subsequent sine loading at various frequencies, and finally followed by the unloading phase for the embedded sensor.

A typical pre-loading change in capacitance with time for the naked sensor is shown in *Figure 6a* and the average change in capacitance over time for all five samples with five repeats per sample in *Figure 6b*. The results showed that after application of a fixed load for five to ten seconds, the sensor capacitance was within 5% of the capacitance value that was measured at the end of the experiment. A similar sensor response pattern was seen from the sensor embedded in the UKR bearing (*Figures 7a & 7b*). In the case of the embedded sensor the measured capacitance reached to within 5% of the capacitance value measured at the end of the experiment.

The mean value of the bare sensor capacitance varied by 10% over the frequency range 0.1 to 10 Hz (*Figure 8*). The median of the normalized capacitive amplitude change was $2 * 10^{-15} F$ [99.3 % CI: 0.67 – 8], when stimulated with 33 N (*Figure 8*). This yielded a medium sensitivity of $6.1 * 10^{-17} F/N$ [99.3 % CI: 2.0 – 24], and a stress sensitivity of $4.5 * 10^{-17} F/MPa$ [99.3 % CI 1.5 – 18]. The amplitude fitted when with the single sinusoidal model was within -3 dB for all frequencies up to 10 Hz for both the naked sensor and the sensor embedded within the UKR bearing (*Figure 9*). The phase decreased to a median of -30 degrees at 10 Hz.

For reference purposes the amplitude transfer function and phase of the actuator load to actuator movement (*Figure 10*) are given, as well as the amplitude transfer function and phase of the actuator movement to capacitive change, all measured using the bearings with embedded sensors.

267 Harmonic distortion analysis showed that predominantly a second harmonic frequency was
268 generated (dotted line *Figure 11*) with a median amplitude in the range of 5% of the first
269 harmonic for the naked sensor, and 20% for the embedded sensor. Above 8 Hz only a first
270 harmonic frequency was noted.

4 Discussion

This paper explored the feasibility of a capacitive load sensor embedded within the polyethylene bearing of a unicompartamental knee replacement. To our knowledge this has not previously been achieved. A flexible capacitive load sensor was developed that could be incorporated within the standard compression moulding manufacturing process of the Oxford UKR polyethylene bearing. Subsequent testing using a uniaxial servo-hydraulic material testing machine showed that the embedded sensor was capable of measuring forces within the polyethylene bearing.

It was demonstrated that adding diverging limbs in order to position the sensor within the mould tool (*Figure 3a*) was a simple and reliable way of centring the sensor within the bearing during manufacturing. The sensor was built using three layers of electrode, with the electrically driven electrode of the capacitor on both sides of the sensing electrode which was situated in the middle. This was done in order to isolate the sensing electrode from electromagnetic interference, similar to the use of extra shielding layers [33]. Using the driving electrodes instead of extra shielding resulted in the sensor being 35% thinner and more flexible. Additionally, adding extra layers adds manufacturing cost. Although the precise signal to noise ratio was not measured, there were no problems due to noise.

The development of a sensor which can be embedded within polyethylene represents a significant step towards the realization of an instrumented mobile UKR and to addressing the disadvantages of current instrumented implants. Our sensor was produced using commercially available construction methods and therefore the costs of manufacturing are lower compared to custom manufacturing. Furthermore, custom manufacturing methods often utilise 3D-printing, which uses polymers with a low melting temperature, and therefore would pose a major concern with respect to shape retention at the high temperatures and pressures [30] experienced during compressive

moulding. Polyamide is especially suited as a sensor because of its tolerance of high temperatures [34]. The use of a flexible capacitive load sensor meant that the sensor could be placed within the polyethylene bearing using the standard manufacturing process of polyethylene bearings, offering significant additional cost advantages. Furthermore this also opens up the possibility of load measurement in larger numbers of implants and different types of joint replacement. The use of a sensor within the bearing reduces the complexity and the need for moving parts compared to previous instrumented knees [8, 9]. In addition to the technological advances described, there is the intra-operative benefit of the procedure remaining unchanged as no additional bone resection would be required.

Viscous sensor response and pre-loading

The load sensor embedded in polyethylene exhibited a visco-elastic behaviour which prevented traditional load measurement and calibration methods from being used. Instead, an initial static load was required to achieve a quasi-steady state static sensor output; after which dynamic load perturbations could be measured centred around the static load point. For the naked sensor foil, polyimide, this pre-loading time was 10 seconds. The pre-loading compression curve showed that for the polyimide foil, after reaching quasi steady state, beyond 90 seconds the confidence interval increased (*Figure 6*), potentially signifying capacitive drift. This behaviour was not observed in the capacitive sensor embedded within the bearing.

Embedding the sensor in the UHMWPE bearing resulted in a quasi-static response only being observed after 13 minutes under pre-load. The slower response compared to PI was probably due to a number of factors. UHMWPE does not have a linear stress-strain curve, and exhibits a time dependent stress-strain behaviour. Furthermore, the geometry of the bearing was not simple. Manufacturing tolerances cause the concavity of the bearing to deviate from conformity with the

319 radius of the femoral component; thus it is preferred to have a smaller femoral component outer
320 radius and a larger bearing internal radius. This is because if the bearing radius was smaller than
321 that of the femoral component, there would be a perpendicular outwardly acting force within the
322 bearing during compression, which could lead to edge loading and increased susceptibility to
323 failure. Therefore, even in normal loading the highest load is concentrated at the centre of the
324 bearing concavity, which then experiences a higher stress than the surrounding polyethylene.
325 During the relaxation period prior to achieving quasi steady state, more and more of the load is
326 distributed outwards from the centre of the concavity. This largely explains the longer pre-loading
327 stage; it can be seen that initially the capacitance increases sharply, due to the concentrated load
328 in the middle of the bearing where the sensor resides, but then as the UMPWHE compresses
329 locally, the load spreads outwardly and the capacitance change lessens.

330 Previous literature has not referred to the viscous response of their sensor in detail [18-25, 33],
331 although Laszczak *et al.* [33] possibly hinted at this based on the statement “*a specific tare load*
332 *was applied to the sensor for 30 s... this strategy minimized a possible transient response*
333 *resulting from the viscoelastic behaviour of the Elastomer*”. Unfortunately, details about the tare
334 load were not described, nor were details about the effectiveness of pre-loading in their
335 experiment, making direct comparison to their results difficult.

336 Pre-loading in a practical scenario

337 Applying a pre-load for 13 minutes prior to measurement is a limitation. In practice, this could
338 mean that before a physiological loading measurement can be recorded, a patient with an
339 instrumented UKR should load the bearing by means of standing, walking, or running. We suspect
340 that additional data could be obtained from experiments that do not feature pre-loading, but it
341 would require a different calibration or more post-processing, which would need to be investigated
342 further.

343

344 Calibration

345 Given that the range of temperatures the bearing will experienced in vivo is likely minimal given
346 the tight self-regulation of temperature by the body, we do not expect problems due to temperature
347 fluctuations. However this does needs to be investigated further. Additionally bearings would need
348 to be individually calibrated prior to implantation. This would have to be done under pre-specified
349 conditions and would also require further investigation.

350

351 Frequency Response

352 The tests showed that the compression response of the instrumented bearing to frequencies
353 between 0.1 to 10 Hz was close to linear if a steady state pre-load corresponding to body mass
354 was applied for at least 13 minutes prior to measurement.

355 The frequency response showed a low pass filter response, with a close to linear amplitude above
356 -3 dB and up to 10 Hz. Therefore the sensor should be able to measure typical loading scenarios,
357 such as gait where the predominant signal frequency is in the region of 1 Hz with a maximum
358 signal content of 4.2 Hz [29]. Our findings suggest that the materials testing machine was not
359 responsible for the observed low pass behaviour, given the constant phase we recorded between
360 measured actuator load and actuator position (*Figure 10c*), *whereas the phase change is*
361 *introduced in (Figure 10d)*. Furthermore, our capacitance to digital converter measured at a
362 frequency of 90 Hz, which ruled out its influence. We did observe characteristic low pass phase
363 behaviour between actuator position (compression of the bearing) and capacitance increase,
364 indicating that the sensor foil itself was causing low pass behaviour. Therefore, we ascribe this
365 behaviour to the increasing incompressibility of the sensor foil construct, starting at frequencies
366 above than 1 Hz.

367

368 Harmonic Frequency Generation

Harmonic frequency generation occurs as a result of a nonlinear load-strain relationship, and therefore, the output signal will have a different shape to the input signal. The measured second harmonic of 5% for the naked sensor foil was minimal and may be neglected, but a larger second order harmonic with an amplitude of 20% was observed in the embedded sensor which has the potential to be problematic. To what extent requires further investigation with actual physiological signals. A limitation was that above 8 Hz the method stopped working accurately; only the first harmonic was detected. This was most likely due to signal noise rather than the absence of second order frequency generation.

Sensitivity

A medium sensitivity of $6.1 * 10^{-17}$ F/N [99.3 % CI: 2.0 – 24] was achieved, and a stress sensitivity of $4.5 * 10^{-17}$ F/MPa [99.3 % CI 1.5 – 18]. The stress sensitivity that was obtained with the sensor was more than 44 times lower ($2 - 4 * 10^{-17}$ F/MPa) than that of a comparable polyimide sensor [19] which had slots that allow for the polymer to expand more under compression with identical loads. Conversely, our sensor does not suffer from nonlinearity at lower loads.

Loading Magnitudes

In our study the peak load was 683 N. Using the 50-50 % load distribution between medial and lateral side of a knee [26-28], this equals a maximum load of 1366 N. In instrumented TKR, the peak force has ranged up to 4200 N [35]. Because of the use of sinusoidal waveforms required to measure frequency transfer characteristics of our sensor, we were limited to applying reduced peak loads. Further measurements are needed with gait loading patterns with equivalent loads to those measured using instrumented TKR [29].

Implant Development

Further development is required before a standalone embedded load sensor within a UKR can be used. The next step is that development of an embedded electronic system for recording and communication of data. Although communication with implanted sensors has been achieved before [8, 9], achieving this while at the same time meeting the requirements of being small enough to fit in a UKR bearing and being incorporated during the compression moulding process presents a significant challenge. The optimal positioning of a sensor and communication module within the bearing would need to be determined; we suggest this could initially be done with finite element based simulation, and subsequently using mechanical testing, before using the device *in-vivo*.

Also the potential use of such sensors in other implants using polyethylene bearings, such as total hip replacements, total knee replacements opens the scope of future applications. As these implants are larger, multiple sensors could be placed in a grid-like fashion, making it possible to measure load distribution and contact points.

5 Conclusion

We have developed a novel capacitive load sensor that can be embedded in UKR bearings, and potentially other joint replacement bearings, using standard production methods, and have assessed its dynamic sensitivity, frequency response and nonlinear distortion. We found that to obtain repeatable results, the instrumented bearing has to be pre-loaded for 13 minutes. The requirement for pre-loading was not due to the sensor but was a manifestation of the complex viscous-elastic behaviour of the UHMWPE component. After pre-loading there was a linear response to superimposed dynamic loading frequencies, with a low pass filter characteristic with a -3 dB frequency of 10 Hz. Each sensor had dimensions of 2x2 mm, a median load sensitivity of 6.1×10^{-17} F/N [99.3% CI: 0.67-8], and a median stress sensitivity of 4.5×10^{-17}

417 F/MPa [99.3 % CI: 1.5-18]. We conclude the sensor could be used to measure physiological loads,
418 spanning the physiological frequency range.

419

420

421

422

423

424 **Figures**

425

426 **Figure 1:** Illustration showing the layout of the common and middle electrodes, made of a layer
 427 of solid copper foil

428

429

430 **Figure 2:** Illustration showing the composition of the capacitive sensor layers, where *PI* =
 431 Polyimide, *adh* = adhesive, *Cu* = copper. For each layer, the thickness is given in micrometers
 432 (μm).

433

Figure 3: (a) (top left) the sensor assembly with the capacitive sensors in the middle, and three extending legs for centring the sensor within the mould. The sensor leads were folded in a harmonica fold. (b) (top right) The sensor within the mould on half of the UHMWPE powder. (c) (bottom left) the moulded UKR bearing with the embedded sensor. (d) (bottom right) the folded sensor leads were recovered with a hot cutting tool and unfolded.

NOTE TO EDITOR: WE ARE EXPECTING THAT YOU PREFER TO ADD THE INDIVIDUAL LABELS YOURSELF. If not, please contact us and we'll add (a),(b),etc.

443

444 **Figure 4:** (a)(left) Diagram of the servo-hydraulic loading rig setup, showing hydraulic actuator,
 445 femoral component, sensor foil, bearing, glass base, and C2D (capacitance to digital converter),
 446 and (b)(right) the identical setup but testing a bearing sample.

447 NOTE TO EDITOR: WE ARE EXPECTING THAT YOU PREFER TO ADD THE INDIVIDUAL
 448 LABELS YOURSELF. If not, please contact us and we'll add (a),(b),etc.

449

450

451 **Figure 5:** Plot of capacitance vs. time for a full measurement cycle of an instrumented bearing.
 452 The sinusoidal loads are 10 seconds each of 0.1 Hz up to 1 Hz in steps of 0.1 Hz, and 1 Hz to 10
 453 Hz in steps of 1 Hz, with ± 293 N amplitude.

454

455

456

457 **Figure 6:** Plots showing capacitance against time for pre-loading of the naked sensors. The raw
 458 data of a single sample is illustrated in (a)(left) and (b)(right) an overview of results for all 5
 459 samples with 5 repeats per sample (25 in total). No load equals 0 % and maximum median
 460 capacitance equals 100 %, Note that greater than 95 % of the steady-state value was reached
 461 within 10 seconds. The red data points are the outliers of the distribution shown by each box plot.
 462 NOTE TO EDITOR: WE ARE EXPECTING THAT YOU PREFER TO ADD THE INDIVIDUAL
 463 LABELS YOURSELF. If not, please contact us and we'll add (a),(b),etc.

464

465

Figure 7: Plots showing capacitance against time for pre-loading of the instrumented sensors. The raw data of a single sample is illustrated in (a) (left) and an overview of results for all samples in (b) (right). Note that greater than 95 % of the steady-state value was reached within 13 minutes. The red data points are the outliers of the distribution shown by each box plot.

NOTE TO EDITOR: WE ARE EXPECTING THAT YOU PREFER TO ADD THE INDIVIDUAL LABELS YOURSELF. If not, please contact us and we'll add (a),(b),etc.

475

476 **Figure 8:** Normalised amplitude (peak to peak) capacitive change of the bare sensor foil for 33 N
 477 sinusoidal loading, based on 5 sensors for a total of 25 measurements. The 99.3% CI typically
 478 lies between 0.67 and 8 fF. The black dots represent the means of each individual sensor foil (5
 479 experiments each). The results of two measurements, below 2, partially overlap.

480

Figure 9: Normalised load to capacitance amplitude frequency transfer response for the (a)(top left) naked sensor foil, and (b)(top right) sensor embedded within the bearing, and the phase responses for (c)(bottom left) the naked sensor foil and (d)(bottom right) the sensor embedded within the bearing. The red points are outliers as of a result of showing the distribution as a boxplot.

NOTE TO EDITOR: WE ARE EXPECTING THAT YOU PREFER TO ADD THE INDIVIDUAL LABELS YOURSELF. If not, please contact us and we'll add (a),(b),etc.

Figure 10: (a) Normalised load to actuator position amplitude frequency transfer response, (b) normalised actuator position to capacitance frequency transfer response, (c) load to actuator position phase response, and (d) actuator position to capacitance change phase response, all for the sensor embedded within the bearing. The red points are outliers as of a result of showing the distributions as a boxplot.

NOTE TO EDITOR: WE ARE EXPECTING THAT YOU PREFER TO ADD THE INDIVIDUAL LABELS YOURSELF. If not, please contact us and we'll add (a),(b),etc.

504

505 **Figure 11:** Results for the dual sine wave fitting: the ratio of the first to the second harmonic
 506 frequency (a) the naked sensor and (b) the embedded sensor and the ratio of the amplitudes for
 507 (c) the naked sensor and (d) the embedded sensor. The dotted trace shows the best fit to the
 508 means of the distributions. The red points are outliers as of a result of showing the distribution as
 509 a boxplot.

510 NOTE TO EDITOR: WE ARE EXPECTING THAT YOU PREFER TO ADD THE INDIVIDUAL
 511 LABELS YOURSELF. If not, please contact us and we'll add (a),(b),etc.

512

513

514

515

516

517

518

519

520

521

522 **References**

- 523 1. Griffin, T.M. and F. Guilak, *The Role of Mechanical Loading in the Onset*
524 *and Progression of Osteoarthritis*. Exercise and Sport Sciences Reviews,
525 2005. **33**(4): p. 195–200.
- 526 2. Radin, E.L., I.L. Paul, and R.M. Rose, *Role of mechanical factors in*
527 *pathogenesis of primary osteoarthritis*. the Lancet, 1972. **299**(7749): p.
528 519–522.
- 529 3. Meyer, A.J., et al., *Are external knee load and EMG measures accurate*
530 *indicators of internal knee contact forces during gait?* J Orthop Res,
531 2013. **31**(6): p. 921–9.
- 532 4. Walker, P.S., et al., *Preclinical evaluation method for total knees*
533 *designed to restore normal knee mechanics*. J Arthroplasty, 2011. **26**(1):
534 p. 152–60.
- 535 5. Wehner, T., L. Claes, and U. Simon, *Internal loads in the human tibia*
536 *during gait*. Clin Biomech (Bristol, Avon), 2009. **24**(3): p. 299–302.
- 537 6. Fregly, B.J., et al., *Sensitivity of knee replacement contact calculations*
538 *to kinematic measurement errors*. J Orthop Res, 2008. **26**(9): p. 1173–9.

7. D'Lima, D.D., et al., *In vivo contact stresses during activities of daily living after knee arthroplasty*. J Orthop Res, 2008. **26**(12): p. 1549-55.
8. D'Lima, D.D., et al., *An implantable telemetry device to measure intra-articular tibial forces*. J Biomech, 2005. **38**(2): p. 299-304.
9. Heinlein, B., et al., *Design, calibration and pre-clinical testing of an instrumented tibial tray*. J Biomech, 2007. **40** Suppl 1: p. S4-10.
10. Price, A.J., et al., *Simultaneous in vitro measurement of patellofemoral kinematics and forces following oxford medial unicompartmental knee replacement*. J Bone Joint Surg [Br], 2006. **88-B**: p. 1591-5.
11. Pandit, H., et al., *Combined anterior cruciate reconstruction and Oxford unicompartmental knee arthroplasty: in vivo kinematics*. Knee, 2008. **15**(2): p. 101-6.
12. Patil, S., et al., *Can normal knee kinematics be restored with unicompartmental knee replacement?* J Bone Joint Surg Am, 2005. **87**(2): p. 332-8.
13. Price, A.J., et al., *Sagittal plane kinematics of a mobile-bearing unicompartmental knee arthroplasty at 10 years*. The Journal of Arthroplasty, 2004. **19**(5): p. 590-597.
14. Robinson, B.J., et al., *A kinematic study of lateral unicompartmental arthroplasty*. The Knee, 2002. **9**(3): p. 237-40.
15. Yang, K.Y., et al., *Minimally invasive unicondylar versus total condylar knee arthroplasty – early results of a matched-pair comparison*. Singapore Med, 2003. **44**(11): p. 559-62.
16. Pegg, E.C., et al., *Fracture of mobile unicompartmental knee bearings: a parametric finite element study*. Proc Inst Mech Eng H, 2013. **227**(11): p. 1213-23.
17. Micro-measurements, V., in *Strain gage selection – criteria, procedures, recommendations*. 2005: <http://www.vishaypg.com/docs/11055/tn505.pdf>. p. 1-16.
18. Dobrzynska, J.A. and M.A.M. Gijs, *Capacitive flexible force sensor*. Procedia Engineering, 2010. **5**: p. 404-407.
19. Dobrzynska, J.A. and M.A.M. Gijs, *Flexible polyimide-based force sensor*. Sensors and Actuators A: Physical, 2012. **173**(1): p. 127-135.
20. Cheng, M.Y., C.L. Lin, and Y.J. Yang, *Tactile and shear stress sensing array using capacitive mechanisms with floating electrodes*, in *Micro Electro Mechanical Systems (MEMS)*. 2010, IEEE.
21. Kim, B.-C., et al., *Multi-axis Flexible Force Sensor for Tactile Display*, in *Sensors*. 2011. p. 1453-6.
22. Lee, H.-K., et al., *Normal and Shear Force Measurement Using a Flexible Polymer Tactile Sensor With Embedded Multiple Capacitors*. Journal of Microelectromechanical Systems, 2008. **17**(4): p. 934-942.

23. Surapeneni, R., et al., *A highly sensitive flexible pressure and shear sensor array for measurement of ground reactions in pedestrian navigation in Solid-State sensors, Actuators and Microsystems Conference (TRANSDUCERS)*. 2011. p. 906–9.
24. Valdastrì, P., et al., *Characterization of a novel hybrid silicon three-axial force sensor*. Sensors and Actuators A: Physical, 2005. **123–124**: p. 249–257.
25. da Rocha, J.G.V., P.F.A. da Rocha, and S. Lanceros-Mendez, *Capacitive Sensor for Three-Axis Force Measurements and Its Readout Electronics*. IEEE Transactions on Instrumentation and Measurement, 2009. **58**(8): p. 2830–2836.
26. Varadarajan, K.M., et al., *In vivo contact kinematics and contact forces of the knee after total knee arthroplasty during dynamic weight-bearing activities*. J Biomech, 2008. **41**(10): p. 2159–68.
27. D'Lima, D.D., et al., *Tibial forces measured in vivo after total knee arthroplasty*. J Arthroplasty, 2006. **21**(2): p. 255–62.
28. Johnson, F., S. Leitzl, and W. Waugh, *The distribution of load across the knee, a comparison of static and dynamic measurements*. Bone and Joint Surgery, 1980. **62–B**: p. 346–9.
29. www.orthoload.com. 2012; datasets K1L11018_80p_gait and k2I_290409_1_109p].
30. Kurtz, S.M., *The UHMWPE Handbook, Ultra-High Molecular Weight Polyethylene in Total Joint Replacement*. 2004.
31. ISO, *ISO Standard 376:2011 Metallic materials -- calibration of force-proving instruments used for the verification of uniaxial testing machines*. 2011.
32. Meyer, R.W. and L.A. Pruitt, *The effect of cyclic true strain on the morphology, structure, and Relaxation behavior of ultra high molecular weight polyethylene Polymer*, 2001. **42**(12): p. 5293–5306.
33. Laszczak, P., et al., *Development and validation of a 3D-printed interfacial stress sensor for prosthetic applications*. Med Eng Phys, 2015. **37**(1): p. 132–7.
34. Khazaka, M.L., et al., *Effects of mechanical stress, thickness and atmosphere on ageing of polyimide thin films at high temperature*. Polymer Degradation and Stability, 2013. **98**: p. 361–7.
35. Bergmann, G., et al., *Standardized Loads Acting in Knee Implants*. PLOS ONE, 2014. **9**(1): p. e86035.